

**Cleveland Municipal Airport
Aviation Services
[REDACTED]
Cleveland Texas 77327**

To whom it may concern:

After the aircraft accident on July 4, 2015 involving an aircraft that might possibly have been serviced here, we quarantined our fuel facility and ceased all fuel sales and fuel deliveries until after the fuel quality inspection was completed.

Separate samples of aviation gasoline were tested separately from each of the following

TYPE of fuel facilities: above ground, double wall... Please see attached blueprint. The following test were conducted on July 4, 2015 fuel delivery nozzle. There was also an inspection on July 3, 2015 around 5:30 PM and found to be no issues. I personally fueled my plane N172AD and flew to T25 (flight following as well as attached receipt will verify).

White Bucket Tests - When I put a sample of fuel in a clean white bucket, the fuel was the proper color and clarity. There was no evidence of debris or other contamination, and no water was present. The smell and feel of the fuel did not show any evidence of contamination from jet fuel or diesel fuel. (Picture Attached)

White Paper Tests - When I put a sample of fuel on a sheet of clean white paper the fuel evaporated completely 41.83 seconds (Picture Attached) and left a slight stain of the fuel dye with no other residue. The smell of the dried sample on the white paper was the smell of gasoline, and did not have the smell of jet fuel or diesel fuel. There was no evidence of contamination from debris, or water, or jet fuel, or diesel fuel.

Markings on the filter show (Picture Attached) filter system normal. The most recent bulk delivery was about 3935 gallons of fuel received on 5/28/2015.



At the completion of the satisfactory fuel quality tests the quarantine was lifted and fuel deliveries were allowed to resume beginning at July 3, 2015.

On July 3, 2015 / about 5:30 PM / Also Additional Testing July 4, 2015. Clay & Darline Dean performed the tests.



Photo of Satisfactory White Paper Test




Photo of Contact Info

