

Invoice # 2362
Invoice Date 07/24/2016 18:30
Customer Langeard Aviation Inc.
[REDACTED]
Wilmington, DE 19801-2549
Registration N5940
Operator Id [REDACTED]



[REDACTED]
Coatesville, PA 19320
[REDACTED]

Services provided by Signature Flight Support - MQS from 24 Jul 2016 17:00 to 24 Jul 2016 17:00

Service	Description	Quantity	Unit Price	Tax Amount	Total Price
3101	HANDLING CHARGE	1.00	[REDACTED]	[REDACTED]	[REDACTED]
1970	HCDISC ABOVE MIN	1.00	[REDACTED]	[REDACTED]	[REDACTED]
1100	100 LL/AVGAS	35.50	[REDACTED]	[REDACTED]	[REDACTED]
Comments [Fuel Ticket/ASR #: 2514920]					
193600	TENANT DISC	35.50	[REDACTED]	[REDACTED]	[REDACTED]
2005	FED EXCISE-100LL	35.50	[REDACTED]	[REDACTED]	[REDACTED]
2402	ARPT FEE 100LL	35.50	[REDACTED]	[REDACTED]	[REDACTED]
3300	INFRASTRUCTURE FEE	1.00	[REDACTED]	[REDACTED]	[REDACTED]
1916	INFRASTRUCTURE FEE DISCOUNT	1.00	[REDACTED]	[REDACTED]	[REDACTED]
Comments Based tenant					
Subtotal					[REDACTED]
Total (USD):					[REDACTED]
Paid With [REDACTED]					[REDACTED]
Balance Due					\$0.000

Customer Signature

I agree to the credit card amount shown and to perform the obligations set forth in the terms of the issuer's cardholder agreement.

Your feedback is appreciated. Tell us how we did today by logging into

[REDACTED] and entering Access Code: [REDACTED]

Join Signature Status today! Visit www.signatureflight.com and start receiving benefits on your next Signature visit. It's free!

We appreciate your business and your vote in the annual FBO surveys.

Did you know that you can now book discounted hotel rates all over the world through the My Signature Customer Portal? Enroll today at signatureflight.com.

Signature000001

2514920

Base MAS

DATE: <u>7-24-16</u>	TAIL #: <u>N5940</u>
CUSTOMER: <u>SALIMAN</u>	A/C TYPE: <u>YAK</u>

100LL / AVGAS ☐	
AUTO ☐	OIL ☐ : _____ OTHER _____

Gold Cap ☐	Lav ☐	Water ☐	GPU ☐	Hangar ☐
Initials: _____	Initials: _____	Initials: _____	Initials: _____	Initials: _____

SPECIAL REQUESTS:

REQUESTED FUEL AMOUNT: TOP OFF

Meter Reading 2 _____ Finish 342 910.1 Meter Reading 1 _____

AVGAS

Meter Reading 2 _____ Start 342 829.6 Meter Reading 1 _____

← Total Gallons →

Fueler's Initials: <u>[REDACTED]</u>	Unit #: <u>7</u>	On A/C Time: <u>1200</u>	Off A/C Time: <u>1205</u>
--------------------------------------	------------------	--------------------------	---------------------------

DID YOU SECURE OIL/FUEL CAPS AND PANELS?

Received by: (Customer) X

Diff Pressure (psi) _____

Capacity 932.2

Fuel Type	OGU
-----------	-----

Unit # A1

Date 7/24/10

Page 1 of 1

Date 7/24/10

Signature
FLIGHT SUPPORT
A BBA Aviation company

[illegible]

Start Nbr-->

342810.5

Meter Total -->

149.9

932.2

Beginning Balance

327

÷ Filled

149.9

- Pumped

0.9

- Sumped

1108.4

= Book Inventory

1102

Physical Inventory

- 24

Variance - Gain/(Loss)

Signature000003

AIRCRAFT FUELING EQUIPMENT CHECKS

LOCATION: *MQS*

EQUIPMENT ID# *Augas*

MONTH: *Jul*

YEAR: *2016*

DAILY - USE APPLICABLE RATINGS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
1. GENERAL CONDITION	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S					
UNIT CLEAR OF FOD & DEBRIS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S					
LIGHTS/LENSES/HORN/BACKUP ALARM	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C						
BRAKES (HAND, FOOT & EMERGENCY)	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
ANTI SLIP (FOOT CONTROLS & DECK)	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
2. CONDITION OF TIRES AND TREAD	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
3. FUEL/AIR LEAKS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
4. BRAKE (SAFETY) INTERLOCKS (ea. device)	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
5. INTERLOCK OVERRIDE CONTROL SEAL	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
6. HOSES, NOZZLES AND SWIVELS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
7. STATIC REELS, CABLES AND CLAMPS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
8. LIFT PLATFORMS	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						
9. FIRE EXTINGUISHERS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
10. SURGE / WASTE TANKS	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						
11. AIR TANKS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
12. TANKER TROUGHS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
13. BATTERIES COVERED OR ENCLOSED	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
14. FSII RESERVOIR FULL / DRYER 25% BLUE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						
15. DEADMAN CONTROLS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
16. PORTABLE LADDERS SERVICEABLE	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
17. CHOCKS & CONES	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
18. SPILL KIT STOCKED	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
19. OPERATIONAL CONTROLS LABELED	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						
20. FILTER SUMPS - RECORD RATINGS	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A						
21. TANKER SUMPS - RECORD RATINGS	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A						
22. FILTER DIFFERENTIAL PRESSURE = PSI	REFERENCE FUEL FILTER VESSEL RECORD BBA 7.2.06A																														
23. NOZZLE FUELING PRESSURE (40 psi max)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-						
24. TANKER BOTTOM LOAD PRE-CHECK	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S						

IDENTIFICATION OF PERSON
PERFORMING TASKS, OR PERSON
ACCEPTING RESPONSIBILITY THAT
TASKS WERE PERFORMED

RATINGS: S = SATISFACTORY; C = COMMENT (COMMENT REQUIRED IN REMARKS SECTION); N/U = NOT USED; N/A = NOT APPLICABLE

NOTE ALL DISCREPANCIES AND/OR IF UNIT IS OUT OF SERVICE IN REMARKS SECTION OR ON BACK OF PAGE.

SUMP SAMPLE RATINGS: SOLIDS - 1 = CLEAN, 2 = SLIGHT, 3 = PARTICULATE, 4 = DIRTY: WATER - A = BRIGHT, B = HAZY, C = CLOUDY, D = WET, E = SURFACTANTS

REMARKS: *Tail light less than 50% function*
Yellow Beacon OEP New fill adapter installed - 7-21-16

RETAIN ON FILE FOR 24 MONTHS

FORM BBA 7.3.04A

REVISION 4/30/2016

Signature000004