

Tipton Airport
Ft. Meade, Md. 20755

FUELMASTER TRANSACTION LISTING

TRANSACTIONS LISTED BY CUSTOMER ID

From Date: 5/1/2019
Time: 12:00:00AM

To Date: 5/6/2019
Time: 9:03:59AM

Page 1 of 2

Print Date: 5/6/2019 Time: 9:04:37AM

Transactions for CUSTOMER ID: MONUHELIO Monumental Helicopters

Transactions for 00N128KR : Helicopter R-44

Date	Time	TC	Site	User ID	Odometer	Hose	CC#	Prod Unit Cost	Quantity	Total
5/2/2019	6:43:00PM	00	AVLL	000004354		1	4	5.1500	15.00GL	77.25
Summary for : 00N128KR Helicopter R-44						Total for	1	transactions	15.00	77.25

Last Read
Next PM
Miles Until

Transactions for 00N147BA : Helicopter R22

Date	Time	TC	Site	User ID	Odometer	Hose	CC#	Prod Unit Cost	Quantity	Total
5/2/2019	4:51:00PM	00	AVLL	000004354		1	4	5.1500	10.10GL	52.02
Summary for : 00N147BA Helicopter R22						Total for	1	transactions	10.10	52.02

Last Read
Next PM
Miles Until

Transactions for 00N572MD :

Date	Time	TC	Site	User ID	Odometer	Hose	CC#	Prod Unit Cost	Quantity	Total
5/2/2019	6:02:00PM	00	AVLL	000004354		1	4	5.1500	16.10GL	82.92
5/3/2019	4:53:00PM	00	AVLL	000004354		1	4	5.1500	8.60GL	44.29
5/4/2019	10:29:00AM	00	AVLL	000004354		1	4	5.1500	14.00GL	72.10
Summary for : 00N572MD						Total for	3	transactions	38.70	199.31

Last Read
Next PM
Miles Until

Summary for CUSTOMER ID : MONUHELIO

									<u>Quantity</u>	<u>Total</u>
Total for	5	transactions							63.80	328.58

FUELMASTER TRANSACTION LISTING

TRANSACTIONS LISTED BY CUSTOMER ID

From Date: 5/1/2019
Time: 12:00:00AM

To Date: 5/6/2019
Time: 9:03:59AM

Page 2 of 2

Print Date: 5/6/2019 Time: 9:04:37AM

Last Read
Next PM
Miles Until

Product Summary for all Transactions

<u>Product</u>	<u>Description</u>	<u>Transactions</u>	<u>Quantity</u>	<u>Total Cost</u>
4	AVGAS100LL	5	63.80GL	328.58
Total Product Summary:		5	63.80	328.58

Eastern Aviation Fuels, Inc.		KFME Tipton Airport		PRODUCT TYPE		AVGas 100LL		DATE:		May 2019	
Facility (Page 1 of 3)		Line No.		DAILY		1		2		3	
DF1	General Condition										
DF2	Fire Extinguishers										
DF3	Storage Tank Sump (visual & water)*										
Record Sump Sample Rating Results											
DF4	Tank #1 -----> Solid / Water Rating										
DF5	Tank #2 -----> Solid / Water Rating										
DF6	Static Reels, Cables, and Clamps										
DF7	Hoses, Swivels, Nozzles, Couplings & Dust Covers										
DF8	Filter Sumps (visual & water)*										
Record Sump Sample Rating Results											
DF9	Vessel #1										
DF10	Vessel #2										
DF11	Deadman Control										
DF12	Nozzle Fueling Pressure (During Recirculation)										
DF13	Nozzle Fueling Pressure (1st Fueling of Day)										
DF14	Filter Differential Pressure *										
Record Differential Pressure (psi)											
DF15	Vessel #1										
DF16	Vessel #2										
DF17	Security, Fire & Safety										
DF18	Sump Saver (visual & water)*										
DF19	Bulk Air Eliminators*										
Record Sump Sample Rating Results											
DF20	Relaxation Chamber*										
Record Sump Sample Rating Results											
MF1	Initials of Inspector										
MF2	MONTHLY										
MF3	Inspect/Clean Nozzle Screens **										
MF4	Filtration & Free Water Checks (Millipore) (JET ONLY)										
MF5	Static System Continuity (25 ohms or less)*										
MF6	Reel ID# Ohms / Reel ID# Ohms										
MF7	Signs, Labels & Placards										
MF8	Spill Kits										
MF9	Fire Extinguishers										
MF10	Floating Suction										
MF11	Interstial										
REMARKS:											

*Daily 3/16, 3/17, 3/18, 3/19, 3/20, 3/21, 3/22, 3/23, 3/24, 3/25, 3/26, 3/27, 3/28, 3/29, 3/30, 3/31 require actual numerical readings. **Overwing and Single Point nozzle screens. ***Change out DP gauge filter when performing this check.
 Ratings: Solids - (1) Clean / Clear, (2) Slight, (3) Particulate, (4) Dirty / Moisture Content (Water): (A) Bright, (B) Hazy, (C) Cloudy, (D) Wet (free water), (E) Surfactants
 S= Satisfactory, C= Comment, N/U= Not Used, N/A= Not Applicable
 Retain 12 months
 KM-8-2017/ATA 103-2017-1/