



MEMORANDUM FOR RECORD

Eric Alleyne
Air Safety Investigator
National Transportation Safety Board
Office of Aviation Safety - Eastern
Region

NTSB Case Number: ERA21FA165
Georgia Power Risk Management: Shirley Key
Date: 4/9/2021
Subject: Email and telephone correspondence

During this correspondence between NTSB investigator and the Georgia Power Risk Management officer, a brief discussion about the power lines was addressed.

According to Mrs. Key, the airplane collided with the power lines between structures 37 and 38. A photo that Mrs. Keys sent showed the power line down in the ravine. The power line was 65.5 ft above ground level and the diameter of the line was 0.447". The power line supplied power to the Town of Cave Springs.