

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 1, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 5790 GALS
ULLAGE = 4229 GALS
90% ULLAGE= 3227 GALS
TC VOLUME = 5730 GALS
HEIGHT = 53.29 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 74.7 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 3, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 5231 GALS
ULLAGE = 4788 GALS
90% ULLAGE= 3786 GALS
TC VOLUME = 5200 GALS
HEIGHT = 49.14 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.3 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 5, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 4462 GALS
ULLAGE = 5557 GALS
90% ULLAGE= 4555 GALS
TC VOLUME = 4434 GALS
HEIGHT = 43.42 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.7 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 2, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 5571 GALS
ULLAGE = 4448 GALS
90% ULLAGE= 3446 GALS
TC VOLUME = 5526 GALS
HEIGHT = 51.66 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 71.5 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 4, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 4841 GALS
ULLAGE = 5178 GALS
90% ULLAGE= 4176 GALS
TC VOLUME = 4813 GALS
HEIGHT = 46.25 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.1 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 6, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 4250 GALS
ULLAGE = 5769 GALS
90% ULLAGE= 4767 GALS
TC VOLUME = 4219 GALS
HEIGHT = 41.83 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 70.1 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 7, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 4122 GALS
ULLAGE = 5897 GALS
90% ULLAGE= 4895 GALS
TC VOLUME = 4089 GALS
HEIGHT = 40.87 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 71.4 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 8, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 3953 GALS
ULLAGE = 6066 GALS
90% ULLAGE= 5064 GALS
TC VOLUME = 3920 GALS
HEIGHT = 39.60 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 71.9 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 9, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 3686 GALS
ULLAGE = 6333 GALS
90% ULLAGE= 5331 GALS
TC VOLUME = 3666 GALS
HEIGHT = 37.57 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.6 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 10, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 3267 GALS
ULLAGE = 6752 GALS
90% ULLAGE= 5750 GALS
TC VOLUME = 3259 GALS
HEIGHT = 34.35 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 63.1 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 11, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 3113 GALS
ULLAGE = 6906 GALS
90% ULLAGE= 5904 GALS
TC VOLUME = 3110 GALS
HEIGHT = 33.15 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 61.0 DEG F

***** END *****

HOLLYWOOD AVATION
[REDACTED]
PEMBROKE PINES FL
K06206772205001

DEC 12, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 2975 GALS
ULLAGE = 7044 GALS
90% ULLAGE= 6042 GALS
TC VOLUME = 2969 GALS
HEIGHT = 32.08 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 62.8 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 13, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 2834 GALS
ULLAGE = 7185 GALS
90% ULLAGE= 6183 GALS
TC VOLUME = 2821 GALS
HEIGHT = 30.95 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.2 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 14, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 2461 GALS
ULLAGE = 7558 GALS
90% ULLAGE= 6556 GALS
TC VOLUME = 2447 GALS
HEIGHT = 27.95 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.8 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 16, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 1968 GALS
ULLAGE = 8051 GALS
90% ULLAGE= 7043 GALS
TC VOLUME = 1950 GALS
HEIGHT = 23.83 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 72.8 DEG F

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 17, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 1656 GALS
ULLAGE = 8363 GALS
90% ULLAGE= 7361 GALS
TC VOLUME = 1639 GALS
HEIGHT = 21.09 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 74.3 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 18, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 1501 GALS
ULLAGE = 8518 GALS
90% ULLAGE= 7516 GALS
TC VOLUME = 1485 GALS
HEIGHT = 19.68 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 75.0 DEG F

***** END *****

HOLLYWOOD AVATION

PEMBROKE PINES FL
K06206772205001

DEC 19, 2020 12:00 AM

INVENTORY REPORT

T 1:AV GAS
VOLUME = 1136 GALS
ULLAGE = 8883 GALS
90% ULLAGE= 7881 GALS
TC VOLUME = 1129 GALS
HEIGHT = 16.22 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 68.9 DEG F

***** END *****

AST System Monthly Visual Inspection Checklist

Facility Name: Hollywood AviationDate 12/13 Year 2020Facility ID: 850 2238Tank # 89925 Type: SW in secondary containment DW ✓

AST SYSTEM	Standards Checklist	Yes	No	N/A	Initials	Comments
Tank	Tank exterior maintained, not corroded or damaged	✓			TF	
	Overfill protection method check	✓			TF	
	Overfill alarms functioning properly	✓			TF	
Secondary Containment	Containment not damaged	✓			TF	
	Clean, empty, and no water, product or debris	✓			TF	
	Liquid removed from inside containment area	✓			TF	
	Drain valve is closed, secured and not leaking	✓			TF	
Fill Port/Spill Bucket	Fill cover is in good condition and properly color coded	✓			TF	
	Fill cap is tightly sealed, gasket is in good condition	✓			TF	
	Clean, empty, no water, product or debris	✓			TF	
Piping	Anti-siphon valve in working order	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Piping exterior not corroded or damaged	✓			TF	
Release Detection	Electronic interstitial monitoring status not in alarm	✓			TF	
	Visual interstitial monitoring (Krueger gauge, stick, etc.)	✓			TF	
	Electronic monitoring system check	✓			TF	
Dispenser	Shear valves properly anchored	✓			TF	
	Sump clean, empty, and has no water, product or debris	✓			TF	
	Piping maintained, not corroding or leaking	✓			TF	
	Fittings not kinked, cracked, torn, or leaking	✓			TF	
	Sensor is in correct position	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Hoses, nozzles and breakaways not leaking or loose	✓			TF	

Additional Comments:

White bucket AVGas fuel examination/TEST performed, no water found.

AST System Monthly Visual Inspection Checklist

Facility Name: Hollywood AssignmentDate 12/14 Year 2010Facility ID: 8502238Tank # 89925 Type: SW in secondary containment DW ✓

AST SYSTEM	Standards Checklist	Yes	No	N/A	Initials	Comments
Tank	Tank exterior maintained, not corroded or damaged	✓			TF	
	Overfill protection method check	✓			TF	
	Overfill alarms functioning properly	✓			TF	
Secondary Containment	Containment not damaged	✓			TF	
	Clean, empty, and no water, product or debris	✓			TF	
	Liquid removed from inside containment area	✓			TF	
	Drain valve is closed, secured and not leaking	✓			TF	
Fill Port/Spill Bucket	Fill cover is in good condition and properly color coded	✓			TF	
	Fill cap is tightly sealed, gasket is in good condition	✓			TF	
	Clean, empty, no water, product or debris	✓			TF	
Piping	Anti-siphon valve in working order	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Piping exterior not corroded or damaged	✓			TF	
Release Detection	Electronic interstitial monitoring status not in alarm	✓			TF	
	Visual interstitial monitoring (Krueger gauge, stick, etc.)	✓			TF	
	Electronic monitoring system check	✓			TF	
Dispenser	Shear valves properly anchored	✓			TF	
	Sump clean, empty, and has no water, product or debris	✓			TF	
	Piping maintained, not corroding or leaking	✓			TF	
	Fittings not kinked, cracked, torn, or leaking	✓			TF	
	Sensor is in correct position	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Hoses, nozzles and breakaways not leaking or loose	✓			TF	

Additional Comments:

White bucket Argas Test. Performed & no water found

AST System Monthly Visual Inspection Checklist

Facility Name: Hollywood AviationDate 12/15 Year 2020Facility ID: 8502238Tank # 89925 Type: SW in secondary containment _____ DW ☒

AST SYSTEM	Standards Checklist	Yes	No	N/A	Initials	Comments
Tank	Tank exterior maintained, not corroded or damaged	✓			TF	
	Overfill protection method check	✓			TF	
	Overfill alarms functioning properly	✓			TF	
Secondary Containment	Containment not damaged	✓			TF	
	Clean, empty, and no water, product or debris	✓			TF	
	Liquid removed from inside containment area	✓			TF	
	Drain valve is closed, secured and not leaking	✓			TF	
Fill Port/Spill Bucket	Fill cover is in good condition and properly color coded	✓			TF	
	Fill cap is tightly sealed, gasket is in good condition	✓			TF	
	Clean, empty, no water, product or debris	✓			TF	
Piping	Anti-siphon valve in working order	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Piping exterior not corroded or damaged	✓			TF	
Release Detection	Electronic interstitial monitoring status not in alarm	✓			TF	
	Visual interstitial monitoring (Krueger gauge, stick, etc.)	✓			TF	
	Electronic monitoring system check	✓			TF	
Dispenser	Shear valves properly anchored	✓			TF	
	Sump clean, empty, and has no water, product or debris	✓			TF	
	Piping maintained, not corroding or leaking	✓			TF	
	Fittings not kinked, cracked, torn, or leaking	✓			TF	
	Sensor is in correct position	✓			TF	
	Piping not in contact with soil/debris	✓			TF	
	Hoses, nozzles and breakaways not leaking or loose	✓			TF	

Additional Comments:

White bucket Argas test performed & no water found

Hollywood Aviation

[REDACTED]
Pembroke Pines, FL 33

[REDACTED]
12-14-2020 18:37:50

FUEL: 100 LL PUMP #1
25.85 @ \$4.090/GAL \$ 105.73

TOTAL \$ 105.73

VISA

CARD: [REDACTED]

NAME: PACETTI/ANTHONY

INVOICE: 206465

APPROVAL: 000010

Price Includes All Taxes

HAVE A SAFE FLIGHT

Tony

N5547Y

Hollywood Aviation

[REDACTED]
Pembroke Pines FL 33

[REDACTED]
12-14-2020 20:00:31

FUEL: 100 LL PUMP #1
8.51 @ \$4.090/GAL \$ 34.81

TOTAL \$ 34.81

AMEX

CARD: [REDACTED]

NAME: MCHALE/RYAN J

INVOICE: 206467

APPROVAL: 520767

Price Includes All Taxes

HAVE A SAFE FLIGHT