

AVGAS FUELING EQUIPMENT CHECKS					STATION: DTS							FACILITY: AVGAS 2							MONTH: MAY							YEAR: 2024						
DAILY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
1. GENERAL CONDITION	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C		
2. FILTER SUMPS - RECORD RATINGS	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A		
3. DEADMAN CONTROLS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
4. SAFETY INTERLOCKS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
5. HOSES, NOZZLES & SWIVELS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
6. STATIC REELS, CABLES & CLAMPS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
7. FIRE EXTINGUISHERS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
8. AIR TANKS	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		
9. REFUELING TRUCK TROUGHS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
10. REFUELING TRUCK SUMPS	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A		
11. REFUELING BOTTOM LOADING PRE-CHECK	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
12. LADDER(S) CONDITION	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
13. SPILL SUPPLIES	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
14. FUEL MATS	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S		
IDENTIFICATION OF PERSON PERFORMING TASKS	[Redacted]																															

WEEKLY					
1. STATIC SYSTEM CONTINUITY TEST	DATE: 05/10/24	DATE: 05/13/24	DATE: 05/20/24	DATE: 05/27/24	DATE:
REEL ID:	OHMS: 4.91	OHMS: 14.96	OHMS: 12.54	OHMS: 10.24	OHMS:
IDENTIFICATION OF PERSON PERFORMING TASKS	[Redacted]	[Redacted]	[Redacted]	[Redacted]	[Redacted]

REMARKS:	Gear shift display does not work 5/1 - 24 Protective casing on ground wire sheathing off 5/16 - 24 & kinked Bottom load intermittently stops Dorming nozzle will not fuel at low speed. Handle shuts off flow of fuel. 5/23 - Deadman Control Overriding Pepper Fixed
----------	---

CONDITION CODES: S = SATISFACTORY; C = COMMENT (COMMENT REQUIRED IN REMARKS SECTION); N/U = NOT USED; N/A = NOT APPLICABLE

RATING OF SUMP SAMPLES:

SOLIDS: 1 = CLEAN, 2 = SLIGHT, 3 = PARTICULATE, 4 = DIRTY

WATER: A = BRIGHT, B = HAZY, C = CLOUDY, D = WET (FREE WATER), E = SURFACTANTS

RETAIN ON FILE FOR 12 MONTHS

AVGAS FORM 103.04A

1/2023

REMOVE AND REPLACE

Fuel Farm Meter		Front	Rear	Total Both Meters	Farm D.P.	Truck D.P.
End	End	590471.7 ✓				
Start	Start	590403.4 ✓			Loss	
Total	Total	68.3 ✓			Gain	
Turn in date: 5/25/14	Unit Filled: 1	Balanced by: [Signature]	Sumped by: [Signature]		Verification	

--- JetStream Fueling Detail ---

Tail Number: N446KW

Customer Id: 656826

Company:

Fueling 1

Invoice Number: DTS146165

Invoice Date: 5/25/2024 2:21 PM

Fuel Type: 100LL

Gallons Billed: 14.0

Gallons Pumped: 14.0

Fuel Order: TOP OFF

Ordered Date (CST): 05/25/2024 13:53

Approved Date (CST):

Pumped Date (local): 05/25/2024 14:20

Truck: AV2

Front Meter Start: 590457.700

Front Meter End: 590471.700

Rear Meter Start: 0.000

Rear Meter End: 0.000